

## DIVISION 09 00 00—Finishes

### FORMAT

1. Technical specifications content and numbering system shall be based on the most current CSI Master Format.

### BASIS OF DESIGN

1. APSU design standards shall not replace fully developed, project and market specific technical specifications, with 3 manufacturers unless indicated otherwise, e.g., Stanley CorMax. Associate shall utilize the standards as a minimum standard to guide the design.
2. Design guidelines supplement building, fire, and other health, safety and welfare codes, and represent practices APSU has adopted regarding the built environment. Where conflicts arise between codes and guidelines, codes take precedent.
3. Coordinate deviation from guidelines with the University Design and Construction (UDC) Department.

### RELATED SECTION

1. 05—METALS

### GENERAL PROVISIONS

1. For in-house renovation projects, paint, flooring, doorframes, and cove base colors shall be selected in consultation with FPP. Product samples are available in 107 Shasteen, 931-221-6197.
2. Ordinarily and if practical, metal stud partitions shall extend from the finish floor to the deck above, be fully sheathed with gypsum, and have sound attenuating batt insulation.
3. Mechanical rooms, receiving areas, and other utility/service areas shall have a painted CMU finish.

### 09 29 00—GYPSUM SHEATHING

1. Use only 5/8" high impact gypsum in the following applications:
  - Corridors, foyers & monumental stairwells
  - Residence Halls
  - Common use areas
  - Classrooms
  - Use 5/8" plain gypsum in all other non-common use areas, such as offices.

### 09 30 00—TILING

1. Use ½" cementitious backer board installed as substrates for ceramic tile.
2. All glazed tile shall be 8W series.
3. In residence hall toilet/shower rooms floors use 2" x 2" or 1" x 1" ceramic tile.
4. On walls and ceilings, when solid polymer is not used, use 4" x 4" ceramic tile.
5. Formal areas may be considered for 12" x 12" ceramic or porcelain tiles. Review with FPP.

## **DIVISION 09 00 00—Finishes**

### **09 51 23—ACOUSTICAL TILE CEILINGS**

1. Concealed spline ceilings shall not be used.
2. Ceiling tiles shall be 2' x 2' x 5/8" square edge. No 2' x 4' ACT shall be used.
3. Use humidity resistant tile similar to Armstrong Humiguard Plus.
4. Suspension grid shall be ASTM heavy-duty, hot dip galvanized steel with white finished exposed tee, 1" wide, nominal.
5. Do not use acoustical tile ceilings in foyers or other areas subject to air pressure changes or wind loads.

### **09 68 13—TILE CARPETING**

1. Tile carpeting shall only be used in office spaces and conference rooms having low traffic volume and have permanent static protection and durable stain inhibitor.
2. In doorframe conditions, the edge of carpet tile shall be placed with the seam running jamb-to-jamb.

### **09 91 00—PAINTING**

1. Reserved

**End of section**